

**Construction Products (Amendment etc.)
EU Exit) Regulation 2019
Declaration of Performance**



DOP Number NICO 4515 EB + ZP (UKCA)

1. Unique identification code of the product-type:

**4515 EB - 101mm Mild Steel Strong Butt Hinge, Electro-Brassed
4515 ZP - 101mm Mild Steel Strong Butt Hinge, Zinc Plate**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

4515 EB + ZP Parts Electro-brassed or zinc plated

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors, when fitted in accordance with the manufacturer's fitting instructions.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5)

Nico Manufacturing Ltd, 109 Oxford Road, Clacton-on-Sea, ESSEX, CO15 3TJ, United Kingdom

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2): *N/A*

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in UK CPR, Annex V: **System 1**

7. In case of the declaration of performance concerning a construction product covered by a designated standard EN 1935:2002. UK Approved product certification body No 1121- performed the determination of the product type on the basis of type testing (including sampling); initial inspection of the manufacturing plant and of the factory production control and continuous surveillance; assessment and evaluation of factory production control; and issued the certificate of constancy of performance of the product.

UKCA Certificate No.1121-CPR-UK-AC7717

8. UK Technical Assessment :NA

9. Declared performance

| Essential characteristics – Self closing | Performance | Designated Standard |
|--|--|---------------------|
| Initial friction torque with max. Door mass 40 Kg | 1.35Nm | EN 1935:2002 |
| Static load | Static load for deformation = door mass x 2. Static load for overload = door mass x 3 | |
| Load deformation | Passed with a displacement under load: - lateral not more than 0.04mm - vertical not more than 0.10mm and a residual displacement after unloading. - lateral less than 0.00mm - vertical less than 0.04mm | |
| Overload | No breakage of any hinge leaf, knuckle, barrel or pin nor any cracking or deformation visible to normal or corrected vision - the hinged test element remained connected to the frame. | |
| Shear Strength | Passed with a lateral and vertical displacement after unloading not more than 1mm | |
| Hinges for use on fire resistant and/or smoke-control doors; | Grade 1: Suitable for use on fire/smoke resistant door assemblies. | |
| Essential characteristics – Durability | Performance | Designated Standard |
| Durability | Passed a 200,000 cycles test with a maximum wear: - lateral Less than 0.09mm - vertical less than 0.36mm with a maximum frictional torque - after 20 cycles 1.26Nm - after the completion of 200,000 cycles 1.08Nm | EN 1935:2002 |
| Corrosion | Passed Grade 3: 96 hrs | |
| Dangerous Substances Annex ZA3 | The materials in the product(s) do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations. | |

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Mr Ian Harrison (Marketing Director)

Date of issue - 9th November 2021

Nico Manufacturing Ltd. Oxford Road, Clacton-on-Sea, ESSEX, United Kingdom